



NOTE:

- A. ALL RESIDENTIAL SERVICE LINES SHALL BE 4" MIN DIA.
- B. ALL SERVICE LINES SHALL TERMINATE AT THE PROPERTY LINE, WITH THE EXCEPTION OF NEW SUBDIVISIONS, WHICH SHALL TERMINATE 6' BEYOND THE PROPERTY LINE OR AS SHOWN ON PLANS.
- C. DEPTHS OF SERVICE LINES AT THE PROPERTY LINE SHALL BE DETERMINED AS FOLLOWS:
 1. SET TO THE ELEVATION AS NOTED ON PLANS.
 2. WHEN THE GROUND SURFACE AT THE PROPERTY LINE IS HIGHER THAN THE EDGE OF PAVEMENT, THE SERVICE ELEVATION SHALL BE A MIN. OF 6' LOWER THAN THE EDGE OF PAVEMENT ELEVATION.
 3. WHEN THE GROUND SURFACE ELEVATION AT THE PROPERTY LINE IS LOWER THAN THE EDGE OF PAVEMENT THE SERVICE LINE SHALL HAVE MINIMUM 6' OF COVER AT THE PROPERTY LINE. LATERALS WITH COVER OF LESS THAN 5' MUST BE PRE-APPROVED.
- D. CONTRACTOR SHALL USE THE MOST APPROPRIATE TYPE OF CONNECTION (A,B OR C) AS DIRECTED BY THE ENGINEER.
- E. ALL SERVICE CONNECTIONS SHALL BE STANDARD WYE BRANCH FITTINGS OR DISTRICT INSTALLED TAP.
- F. INSPECTION REQUIRED PRIOR TO BACKFILLING OF ALL SIDE SEWERS.
- G. USE MULTI-PURPOSE GLUE WHEN TRANSITIONING FROM PVC TO ABS.
- H. BEDDING AND BACKFILL SHALL MATCH THAT OF THE MAIN LINE.

NTS



RESIDENTIAL SERVICE CONNECTION

STANDARD DRAWING

14

APPROVED: APR 2010